



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 17, 2009

**Re: Washington County
Frontier Local Schools
Self-Monitoring Report Violations
Ohio EPA Permit No. OPT00005*ED
NPDES Permit No. OH0059323
Correspondence (PWW)**

Mr. Troy Thacker, Superintendent
Frontier Local School District
44870 State Route 7
New Matamoras, Ohio 45767

Dear Mr. Thacker:

We have received your self-monitoring reports covering the months of July through September 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	pH	1D Conc	6.5	5.5	7/1/2009
001	Total Suspended Solids	30D Conc	30	56.	7/1/2009
001	pH	1D Conc	6.5	5.3	7/8/2009
001	pH	1D Conc	6.5	5.3	7/14/2009
001	pH	1D Conc	6.5	5.4	7/16/2009
001	pH	1D Conc	6.5	5.6	7/20/2009
001	Total Suspended Solids	1D Conc	45	56.	7/24/2009
001	Total Suspended Solids	30D Conc	30	88.	8/1/2009
001	Chlorine, Total Residual	1D Conc	.038	.2	8/18/2009
001	Total Suspended Solids	1D Conc	45	88.	8/24/2009
001	Total Suspended Solids	30D Conc	30	47.	9/1/2009
001	Total Suspended Solids	1D Conc	45	47.	9/8/2009
001	pH	1D Conc	6.5	6.1	9/15/2009
001	pH	1D Conc	6.5	5.6	9/22/2009

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U.S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614) 644-3469.

If there are any questions, please contact me at (740) 380-5434.

Sincerely,



Stephen Wells
District Representative
Division of Surface Water

SW/jg

- c: Rob McPeck, Frontier School District
- c: Greg Danver, Operator