

Frontier High School
Wash Co
Coer



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

January 22, 2008

Re: Washington County
Frontier High School
Compliance Evaluation Inspection
Correspondence (PWW)

Mr. Troy Thacker, Superintendent
Frontier Local School District
44870 State Route 7
New Matamoras, Ohio 45767

Dear Mr. Thacker:

On January 10, 2008, a Compliance Evaluation Inspection (CEI) was conducted at Frontier High School's wastewater treatment plant. The purpose of the inspection was to determine Frontier's compliance with its National Pollutant Discharge Elimination System (NPDES) Permit. Present for the inspection were Rob McPeck representing Frontier and Stephen Wells representing Ohio EPA, Division of Surface Water, Southeast District Office. A copy of my inspection report is attached. No wastewater samples were collected as part of the inspection.

As a result of my inspection, I have the following comments:


1. Frontier has cleaned out a tank that was full of debris. This has helped the operation of the treatment plant.
2. Frontier has had continuing effluent violations for fecal coliform. Frontier will need to look at the operation of chlorination/dechlorination or ultra-violet disinfection to address the fecal coliform violations. The NPDES renewal application states that chlorination equipment is present at the facility. In discussions with Mr. McPeck, he stated that Frontier was told effluent disinfection was not required. As stated in the NPDES Permit, Part II, Item G states effluent disinfection is not required, but the NPDES Permit effluent limitations shall be met.

Please inform this office on the steps that Frontier will be taking to return to compliance with fecal coliform effluent limitations.

In conclusion, the Frontier Local School District was in non-compliance with its NPDES Permit at the time of inspection, due to fecal coliform violations.

If you have any questions, feel free to contact me at (740) 380-5434.

Sincerely,



Stephen Wells
District Representative
Division of Surface Water

SW/mlm

Attachment

c: Rob McPeck, Frontier Local School

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPT00005*ED	OH0059323	January 10, 2008	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Frontier High School 44870 State Route 7 New Matamoras, OH 45767	10:15 a.m.	August 1, 2005
	Exit Time	Permit Expiration Date
	10:45 a.m.	July 31, 2010

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Rob McPeek, Maintenance Coordinator	(740) 865-2400
Name, Address and Title of Responsible Official	Phone Number
Troy Thacker, Superintendent Frontier Local Schools 44870 State Route 7 New Matamoras, OH 45767	(740) 865-2400

C. AREAS EVALUATED DURING INSPECTION

- | | | |
|-----------------------------------|------------------------------------|----------------------------------|
| <u>U</u> Permit | <u>S</u> Flow Measurement | <u>N/A</u> Pretreatment |
| <u>S</u> Records/Reports | <u>N</u> Laboratory | <u>M</u> Compliance Schedules |
| <u>M</u> Operations & Maintenance | <u>U</u> Effluent/Receiving Waters | <u>S</u> Self-Monitoring Program |
| <u>S</u> Facility Site Review | <u>S</u> Sludge Storage/Disposal | <u> </u> Other |
| <u>N/A</u> Collection System | | |

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See attached letter.



Stephen Wells, Inspector, Ohio EPA, Southeast District Office

1/22/08

Date



Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

1/23/08

Date