



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

October 1, 2009

**Re:** Washington County  
Village of Matamoras  
Self-Monitoring Report Violations  
Ohio EPA Permit No. 0PB00029\*HD  
NPDES Permit No. OH0022331  
Correspondence (PWW)

Mr. Greg Danver, Superintendent  
Village of Matamoras  
800 Grandview Avenue  
P.O. Box 536  
New Matamoras, Ohio 45767

Dear Mr. Danver:

We have received your self-monitoring report covering the months of January through May 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	pH	1D Conc	6.5	6.	3/27/2009
001	Total Suspended Solids	30D Conc	12	12.75	1/1/2009
001	Total Suspended Solids	7D Conc	18	27.5	1/1/2009
001	Total Suspended Solids	30D Qty	7.3	13.9482	1/1/2009
001	Total Suspended Solids	7D Qty	10.9	38.1509	1/1/2009
001	Total Suspended Solids	30D Qty	7.3	8.02846	4/1/2009
001	Total Suspended Solids	7D Qty	10.9	11.0143	4/15/2009
001	Total Suspended Solids	30D Conc	12	28.75	5/1/2009
001	Total Suspended Solids	7D Conc	18	100.	5/1/2009
001	Total Suspended Solids	30D Qty	7.3	37.7638	5/1/2009
001	Total Suspended Solids	7D Qty	10.9	143.981	5/1/2009
001	CBOD 5 day	7D Qty	9.1	12.1385	5/1/2009

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U.S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614) 644-3469.

If there are any questions, please contact me at (740) 380-5434.

Sincerely,



Stephen Wells  
District Representative  
Division of Surface Water

SW/dh