



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

September 18, 2008

**Re:** Washington County  
Riverview Estates  
Self-Monitoring Report Violations  
Ohio EPA Permit No. OPG00021\*GD  
NPDES Permit No. OH0050831  
Correspondence (PWW)

Ms. Lila Follett, Operator  
Washington County Commissioners  
223 Putnam Street  
Marietta, Ohio 45750

Dear Ms. Follett:

We have received your self-monitoring report covering the months of April through June 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	Nitrogen, Ammonia (NH3)	30D Qty	.05	.24898	4/1/2008
001	Chlorine, Total Residual	1D Conc	0.038	.08	5/5/2008
001	Chlorine, Total Residual	1D Conc	0.038	.08	5/6/2008
001	Chlorine, Total Residual	1D Conc	0.038	.11	5/7/2008
001	Chlorine, Total Residual	1D Conc	0.038	.12	5/12/2008
001	Chlorine, Total Residual	1D Conc	0.038	.08	5/18/2008
001	Chlorine, Total Residual	1D Conc	0.038	.07	5/19/2008
001	Chlorine, Total Residual	1D Conc	0.038	.08	5/20/2008
001	Chlorine, Total Residual	1D Conc	0.038	.14	5/21/2008
001	Chlorine, Total Residual	1D Conc	0.038	.08	6/6/2008
001	Chlorine, Total Residual	1D Conc	0.038	.12	6/25/2008

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U.S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614) 644-3469.

If there are any questions, please contact me at (740) 380-5267.

Sincerely,



Stephen Wells  
District Representative  
Division of Surface Water

SW/dh