




John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



February 6, 2013

Mr. Nick Reinfeld
R and S Land Development, LLC
3070 Wadsworth Road, Suite B
Norton, OH 44203

SUMMIT COUNTY
R AND S LAND DEVELOPMENT, LLC
NON-COMMUNITY, TRANSIENT PWS
PWS ID: OH7736612

SUBJECT: RESCINDING VIOLATION – TCR

Dear Mr. Reinfeld:

Your public water system was issued a notice of violation of Rule 3745-81-21 of the Ohio Administrative Code (OAC) on 1/22/2013 12:00:00 a.m. for the monitoring period of 4Q2012. The sample was collected on 10/11/2012, but the result was not reported until 2/5/2013.

The violation has been rescinded, and the public notice sent with the notice of violation referenced above does not need to be issued at this time.

OAC 3745-81-31 and 3745-89-08 require results to be reported by the 10th day following the month the sample was collected. Further, OAC 3745-89-08 requires the laboratory to report all positive, all repeat sample results, and all samples required by OAC 3745-81-42 (Ground Water Rule) no later than the end of the next business day after the result was obtained. The sample was not reported in accordance with the above rules, and this is considered a reporting violation.

Please ensure future sample results are submitted as required. If you have any questions, please contact this office at (330) 963-1227.

Sincerely,

A handwritten signature in black ink that reads "Ursula Musselman". The signature is fluid and cursive.

Ursula Musselman
Environmental Specialist
Division of Drinking and Ground Waters

UM:ds

cc: Summit County Health Department
Adams Lab