



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 9, 2010

Re: Jefferson County
Valley Converting Company, Inc.
Notice of Violation
Correspondence (IWW)

Mr. Michael Biasi, President
Valley Converting Co., Inc.
P.O. Box 279
Toronto, Ohio 43694

Dear Mr. Biasi:


We have received your self-monitoring reports covering the months since January 1, 2010 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

The following are the reported violation(s) since January 1, 2010:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00310	Biochemical Oxygen Dem	30D Qty	116	159.692	2/1/2010
001	00310	Biochemical Oxygen Dem	30D Qty	116	158.307	3/1/2010
001	00310	Biochemical Oxygen Dem	30D Qty	116	124.869	4/1/2010

Valley Converting continues to address the difficulty in meeting the permitted BOD₅ limits. During the previous inspection, Valley Converting suggested that they were going to investigate the C:N:P ratio of the effluent and also influent to the activated stabilization basin. Please notify our office when the results are available for review. If you have any questions, please feel free to contact me at (740) 380-5272.

Sincerely,


Aaron Pennington
District Representative
Division of Surface Water

AMP/dh