



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 21, 2011

Re: Jefferson County
Valley Converting Company, Inc.
Notice of Violation
Correspondence (IWW)

Mr. Michael Biasi, President
Valley Converting Co., Inc.
P.O. Box 279
Toronto, Ohio 43694

Dear Mr. Biasi:

We have received your self-monitoring reports covering the months of June 2010 through May 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Parameter	Limit Type	Limit	Reported Value	Violation Date
pH	1D Conc	6.5	5.8	8/1/2010
Biochemical Oxygen Demand	1D Qty	231	247.198	9/15/2010
Biochemical Oxygen Demand	30D Qty	116	184.774	12/1/2010
Biochemical Oxygen Demand	1D Qty	231	260.207	12/22/2010
Biochemical Oxygen Demand	30D Qty	116	128.648	2/1/2011
Biochemical Oxygen Demand	30D Qty	116	197.116	3/1/2011
Biochemical Oxygen Demand	1D Qty	231	309.219	3/9/2011
Biochemical Oxygen Demand	1D Qty	231	234.215	3/16/2011
Biochemical Oxygen Demand	30D Qty	116	152.937	4/1/2011
Biochemical Oxygen Demand	1D Qty	231	298.591	4/20/2011

Your non-compliance notifications for the above violations have been reviewed. A supplement nutrient feed of urea and potentially some phosphorous has been identified to assist in obtaining compliance with Five-day Biochemical Oxygen Demand limits.

If you have any questions, please feel free to contact me at (740) 380-5272.

Sincerely,

Aaron Pennington
District Representative
Division of Surface Water

AMP/dh