




John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



**NOTICE OF VIOLATION – ACTION REQUIRED**

January 22, 2013

Mark Clingan  
P.O. Box 2554  
Lancaster, OH 43130

Fairfield County  
Gloryland Church Of The Nazarene PWS  
NON-TRANSIENT NON-COMMUNITY PWS  
PWD ID: OH2347612

Dear Public Water System Owner:

The Public Water System serving GLORYLAND CHURCH OF THE NAZARENE PWS is in violation of the Ohio Administrative Code (OAC) for:

**Language for Sanitary Survey (SS) Violations**

Failure to respond in Writing within 30 days

*This letter is notification that the Gloryland Church Of The Nazarene PWS has not complied with requirements issued during this Agency's last survey performed on September 26, 2012, in violation of rule 3745-81-60 of the Ohio Administrative Code. The PWS was notified in correspondence dated (DATE), to respond in writing no later than 30 days, with time frames for:*

**REQUIREMENTS**

Per Ohio Administrative Code (OAC) 3745-81-60(D), a responsible official of the public water system must respond in writing and within 30 days, indicating how and on what schedule the system will address the requirements outlined below:

1. Grade the soils around the wellhead to promote positive drainage away from the casing, affix the conduit firmly into the well cap, and protect the well from vehicular traffic with the use of bumper posts or boulders.
2. Keep the brine tank on the softener full of salt and ensure the use of NSF or ANSI approved salt only. Look for the NSF logo on the back of the bags. Ensure the chlorine is also NSF or ANSI approved.

Mark Clingan  
Page -2-

3. Provide for an air gap for the treatment units (six pressure filters and the softener) of at least 2 pipe diameters above the flood rim. This was required after previous surveys.
4. Keep the log book updated w/any repairs or modifications to the system. Write the name public water system ID number of the facility in the front of the logbook. This was required of you after last survey too.
5. The chlorine meters are calibrated in accordance with manufacturer recommendations. We have the same type of meters at EPA and have bought standards that we compare to in house.
6. Place a copy of your license conspicuously in an area accessible to the general public.

Please respond in writing on or before February 21, 2013. An email is fine, the email address is [mark.boden@epa.state.oh.us](mailto:mark.boden@epa.state.oh.us).

If you have any questions please call your Ohio EPA representative at (614) 728-3871.

Sincerely,



Mark Boden  
Environmental Specialist  
Division of Drinking and Ground Waters  
Central District Office

ec: CDO DDAGW AA (State Violation)