



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

January 22, 2013

Dottie Baucum
4888 Refugee Road NW
Baltimore, OH 43105

Fairfield County
New Beginnings Baptist Church PWS
TRANSIENT NON-COMMUNITY PWS
PWD ID: OH2351412

Dear Public Water System Owner:

The Public Water System serving NEW BEGINNINGS BAPTIST CHURCH PWS is in violation of the Ohio Administrative Code (OAC) for:

Language for Sanitary Survey (SS) Violations

Failure to respond in Writing within 30 days

This letter is notification that the New Beginnings Baptist Church has not complied with requirements issued during this Agency's last survey performed on September 11, 2012, in violation of rule 3745-81-60 of the Ohio Administrative Code. The PWS was notified in correspondence dated September 24, 2012, to respond in writing no later than 30 days, with time frames for:

1. Once you have picked out an alternate lab, fill out the attached sample siting plan and maintain it on site, and send a copy of the first page to this office.
2. Protect the wellhead with the use of boulders or bumper posts.
3. Contact this office before making any substantial changes to your water system, plan approval is required.
4. Ensure the brine tank on the softener remains full of salt at all times, it was nearly empty during the survey. Also, use only NSF or ANSI approved salt in your softener.

Dottie Baucum
Page -2-

Please respond in writing on or before February 21, 2013. An email is fine, my email address is mark.boden@epa.state.oh.us.

If you have any questions please call your Ohio EPA representative at (614) 728-3871.

Sincerely,



Mark Boden
Environmental Specialist
Division of Drinking and Ground Waters
Central District Office

ec: CDO DDAGW AA (State Violation)

MB/ct 2351412(FR)SanitarySurveyOCT2012