



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

January 22, 2013

Ed Smith
1200 Delmont Road
Lancaster, OH 43130

Fairfield County
JD Equipment Inc PWS
TRANSIENT NON-COMMUNITY PWS
PWS ID: OH2351312

Dear Public Water System Owner:

The Public Water System serving JD EQUIPMENT INC PWS is in violation of the Ohio Administrative Code (OAC) for:

Language for Sanitary Survey (SS) Violations

Failure to respond in Writing within 30 days

This letter is notification that JD Equipment has not complied with requirements issued during this Agency's last survey performed on September 10, 2012, in violation of rule 3745-81-60 of the Ohio Administrative Code. The PWS was notified in correspondence dated September 24, 2012 to respond in writing no later than 30 days, with time frames for:

1. Once you have picked out an alternate lab, fill out the sample siting plan and maintain it on site, and send a copy of the first page to this office.
2. Protect the wellhead with the use of boulders or bumper posts and remove the orange cone from the top of the casing.
3. Fill out and post the public notice (attached) for seven days to comply with an outstanding violation. Then, within 10 days of issuing the notice, fill out the verification form on the backside and send copies to this office.
4. Ensure the RPZ backflow assembly protecting your drinking water is inspected every 12 months by an Ohio Department of Commerce registered backflow prevention specialist. A list of contractors can be found at:
https://www.comapps.ohio.gov/dic/dico_apps/bdcc/CertifiedBackFlowTesters/
5. Contact this office before making any substantial changes to your water system, plan approval is required.


Ed Smith
Page -2-

6. Post your License to Operate (LTO) in a public place where both employees and the general public can view it.

Respond in writing on or before February 21, 2013. An email is fine, my email address is mark.boden@epa.state.oh.us.

If you have any questions please call your Ohio EPA representative at (614) 728-3871.

Sincerely,



Mark Boden
Environmental Specialist
Division of Drinking and Ground Waters
Central District Office

ec: CDO DDAGW AA (State Violation)

MB/ct 2351312(FR)SanitarySurveyOCT2012