



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

February 4, 2013

Jerry Lemay
13117 Cooksey Road
Utica, OH 43080

Licking County
First Baptist Church Of Utica PWS
TRANSIENT NON-COMMUNITY PWS
PWS ID: OH4562512

Dear Public Water System Owner:

The Public Water System serving FIRST BAPTIST CHURCH OF UTICA PWS is in violation of the Ohio Administrative Code (OAC) for:

Failure to respond in Writing within 30 days

This letter is notification that the First Baptist Church of Utica has not complied with requirements issued during this Agency's last survey performed on 11/8/12, in violation of rule 3745-81-60 of the Ohio Administrative Code. The PWS was notified in correspondence dated 11/20/12 to respond in writing no later than 30 days with time frames for:


1. Protection (i.e., boulders or posts) for the well (Well 0001) must be installed around the well to prevent the well from being damaged by lawn care activities or other traffic. Please send a photo of the protection to this office once it is installed.
2. The cap of the well has a crack on it. This is a potential source of contamination. The cap must be replaced. Please send a photo of the new well cap once it is replaced.
3. All public water systems are required by Ohio Administrative Code rule 3745-81-21 to prepare and maintain a written sample siting plan for the collection of total coliform bacteria samples at sites which are representative of water throughout the distribution system. The plan identifies routine and repeat sampling locations to collect bacteriological samples according to a written Sample Siting Plan. We gave you a copy of a sample siting plan during the sanitary survey. Please send a copy of the first page of the sample siting plan to this office once it is completed.

Jerry Lemay
Page -2-

Please provide a written response providing a schedule for compliance with each of the requirements within 13 days of the date of this letter. An email is fine, my email address is mark.boden@epa.state.oh.us.

If you have any questions please call me at (614) 728-3871.

Sincerely,



Mark Boden
Environmental Specialist
Division of Drinking and Ground Waters
Central District Office

ec: CDO DDAGW AA (State Violation)

MB/ct 4562512(FR)SanitarySurveyNOV2012