

**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 1, 2011

**Re:** Meigs County  
Pomeroy WTP  
Self-Monitoring Report Violations  
Ohio EPA Permit #01Y00102  
NPDES Permit #OH00128198  
Correspondence (IWW)

Mr. Paul Hellman, Village Administrator  
320 East Main Street  
P.O. Box 666  
Pomeroy, Ohio 45769

Dear Mr. Hellman:

We have received your self-monitoring reports covering the month of September 2010 through April 2011, for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:


Outfall	Date	Parameter	Reported	Units	Permit Limit
001	10/21/2010	Manganese, Suspended	3036.	ug/l	2000
001	10/1/2010	Manganese, Suspended	3036.	ug/l	1000
001	10/21/2010	Manganese, Suspended	.3884	ug/l	0.24
001	10/1/2010	Manganese, Suspended	.3884	ug/l	0.12
001	2/10/2011	Total Suspended Solids	95.	mg/l	45
001	2/1/2011	Total Suspended Solids	95.	mg/l	30
001	2/10/2011	Total Suspended Solids	12.1536	mg/l	5.50
001	2/1/2011	Total Suspended Solids	12.1536	mg/l	3.67
001	2/10/2011	Manganese, Suspended	48986.	ug/l	2000
001	2/1/2011	Manganese, Suspended	48986.	ug/l	1000
001	2/10/2011	Manganese, Suspended	6.26693	ug/l	0.24
001	2/1/2011	Manganese, Suspended	6.26693	ug/l	0.12
001	4/7/2011	Total Suspended Solids	63.	mg/l	45
001	4/1/2011	Total Suspended Solids	63.	mg/l	30
001	4/7/2011	Total Suspended Solids	8.05978	mg/l	5.50
001	4/1/2011	Total Suspended Solids	8.05978	mg/l	3.67

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Within 30 days of receipt of this letter please provide a timeline for the cleaning out the backwash tanks.

If there are any questions, please contact me at (740) 380-5266.

Sincerely,



Cynthia Yandrich  
District Representative  
Division of Surface Water

CY/dh