



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

October 8, 2008

**Re: Monroe County**  
Village of Woodsfield  
Self-Monitoring Report Violations  
Ohio EPA Permit #01V00130\*DD  
NPDES Permit #OH0030384  
Correspondence (IWW)

Mr. Terry Comstock  
Village of Woodsfield  
39415 Water Works Road  
Woodsfield, Ohio 43793

Dear Mr. Comstock:

We have received your self-monitoring reports covering the months of April through June 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	30	1705.	4/1/2008
001	00530	Total Suspended Solids	1D Conc	45	1010.	4/7/2008
001	00530	Total Suspended Solids	1D Conc	45	510.	4/14/2008
001	00530	Total Suspended Solids	1D Conc	45	4790.	4/21/2008
001	00530	Total Suspended Solids	1D Conc	45	510.	4/28/2008
001	50060	Chlorine, Total Residual	1D Conc	0.038	.4	4/28/2008
001	00530	Total Suspended Solids	30D Conc	30	1095.	5/1/2008
001	00530	Total Suspended Solids	1D Conc	45	1010.	5/7/2008
001	00530	Total Suspended Solids	1D Conc	45	1210.	5/14/2008
001	00530	Total Suspended Solids	1D Conc	45	550.	5/21/2008
001	00530	Total Suspended Solids	1D Conc	45	1610.	5/28/2008
001	50060	Chlorine, Total Residual	1D Conc	0.038	.3	5/28/2008


Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets and U.S. EPA's Facility Pollution Prevention Guide, (EPA/600/R-92/088), you may contact the Ohio EPA Pollution Prevention Section at (614) 644-3469 or me for additional information.

If there are any questions, please contact me at (740) 380-5227.

Sincerely,



Scott Foster  
Environmental Specialist 2  
Division of Surface Water

SF/dh