



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 7, 2009

Re: Monroe County
Woodsfield WTP
2010 CEI
OIV00130*DD
Correspondence (PWW)

Mr. Terry Comstock, Water Supt.
Woodsfield WTP
221 South Main Street
Woodsfield, Ohio 43793

Dear Mr. Comstock:

On August 18, 2009, I conducted a Compliance Evaluation Inspection at the Woodsfield WTP. The purpose of the inspection was to determine the village's compliance with its NPDES permit. I was accompanied by Mark Harrelson, Water Operator and you.

The Village of Woodsfield has discontinued discharging carbon/lime sludge from the settling tanks and filter backwash water into Sunfish Creek. This had been a normal operating procedure for the village since 1977. These discharges regularly violated the effluent limits contained in the NPDES permit. DFFO's were issued to the village on February 11, 2009 ordering the abatement of the unauthorized discharges. Construction of a disposal system for backwash water, lime sludge and septic waste is nearly completed. As soon as the system is operational, the Ohio EPA will terminate your current NPDES permit.

If you have any comments or questions, please feel free to call me at (740) 380-5227.

Sincerely,

Scott Foster
Environmental Specialist 2
Division of Surface Water

SF/dh

Enclosure

c: Jeff Woodell, Village Administrator
c: Mayor and Council
c: Mark Harrelson, Water Operator

**NPDES
Compliance Inspection Report**

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0IV00130*DD	OH0030384	August 18, 2009	C	S	2

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Village of Woodsfield WTP 39415 Water Works Road Woodsfield, Ohio 43793	2:15 PM	June 1, 2003
	Exit Time	Permit Expiration Date
	2:50 PM	May 31, 2008

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Terry Comstock, Superintendent	740-472-0995
Name, Address and Title of Responsible Official	Phone Number
Terry Comstock, Superintendent Village of Woodsfield WTP 670 Old Brick Road Woodsfield, Ohio 43793	740-472-0995


C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>S</u> Flow Measurement	<u>N/A</u> Pretreatment
<u>S</u> Records/Reports	<u>N/A</u> Laboratory	<u>S</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>M</u> Sludge Storage/Disposal	<u>--</u> Other
<u>N/A</u> Collection System		

(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See Attached Letter.



 Scott Foster, Inspector, Ohio EPA, Southeast District Office

10/8/09

 Date



 Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

10/18/09

 Date