



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 2, 2008

Re: Monroe County
Beallsville WWTP
Self-Monitoring Report Violations
Ohio EPA Permit #0PA00000
NPDES Permit #OH0020885
Correspondence (PWW)

Mayor and Council
Village of Beallsville
43057 Ohio Avenue
P.O. Box E
Beallsville, Ohio 43716

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of October 2007 through March 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

| Report Period | Station | Reporting Code | Parameter | Limit Type | Limit | Reported Value | Violation Date |
|---------------|---------|----------------|-------------------------|------------|-------|----------------|----------------|
| Feb 2008 | 001 | 00530 | Total Suspended Solids | 30D Qty | 9.1 | 26.6297 | 2/1/08 |
| Feb 2008 | 001 | 00530 | Total Suspended Solids | 7D Qty | 14 | 116.699 | 2/1/08 |
| Feb 2008 | 001 | 00530 | Total Suspended Solids | 7D Conc | 45 | 82. | 2/1/08 |
| Feb 2008 | 001 | 00610 | Nitrogen, Ammonia (NH3) | 30D Qty | 0.61 | 1.30507 | 2/1/08 |
| Feb 2008 | 001 | 00610 | Nitrogen, Ammonia (NH3) | 7D Qty | 0.91 | 2.27706 | 2/1/08 |
| Mar 2008 | 001 | 00610 | Nitrogen, Ammonia (NH3) | 30D Qty | 0.61 | 1.32172 | 3/1/08 |
| Mar 2008 | 001 | 00610 | Nitrogen, Ammonia (NH3) | 7D Qty | 0.91 | 2.24072 | 3/1/08 |
| Mar 2008 | 001 | 00610 | Nitrogen, Ammonia (NH3) | 7D Conc | 3.0 | 3.2 | 3/1/08 |
| Feb 2008 | 001 | 80082 | CBOD 5 day | 7D Qty | 12 | 35.579 | 2/1/08 |
| Feb 2008 | 001 | 80082 | CBOD 5 day | 30D Qty | 7.6 | 10.8909 | 2/1/08 |
| Mar 2008 | 001 | 80082 | CBOD 5 day | 7D Qty | 12 | 14.0045 | 3/1/08 |


Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets and U.S. EPA's Facility Pollution Prevention Guide, (EPA/600/R-92/088), you may contact the Ohio EPA Pollution Prevention Section at (614) 644-3469 or me for additional information.

If there are any questions, please contact me at (740) 380-5227.

Sincerely,



Scott Foster
Environmental Specialist 2
Division of Surface Water

SF/dh