



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 19, 2008

Re: Monroe County
Village of Clarington
CEI 2009
0PA00037*FD
Correspondence (PWW)

Mr. Larry Bailey, Operator
Village of Clarington WWTP
1029 Market Street
Clarington, Ohio 43915

Dear Mr. Bailey:

On August 13, 2008, I conducted a compliance evaluation inspection for the Village of Clarington's wastewater facility. The purpose of the inspection was to check for the villages' compliance status with its NPDES permit. I was accompanied by you.

The flow meter had not been calibrated for a few years and should be calibrated at least yearly. Regular maintenance should be provided to all equipment in the plant as required by Part III, Item 3(A) of your NPDES permit. You should consult the manufacturers' specifications for calibration frequencies. Without proper calibration, this could lead to erroneous readings being reported on your monthly DMR. An inspection report is attached.

If you have any questions or comments, please feel free to call me at (740) 380-5227.

Sincerely,

Scott Foster
Environmental Specialist 2
Division of Surface Water

SF/dh

c: Lida Conn, Mayor

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0PA00037*FD	OH0021636	August 13, 2008	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Village of Clarington WWTP 1029 Market Street Clarington, Ohio 43915	1:45 p.m.	September 1, 2008
	Exit Time	Permit Expiration Date
	2:15 p.m.	August 31, 2013

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Larry Bailey, Operator	(740) 458-0002
Name, Address and Title of Responsible Official	Phone Number
Lida Conn, Mayor	(740) 458-1652


C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>M</u> Flow Measurement	<u>N</u> Pretreatment
<u>S</u> Records/Reports	<u>S</u> Laboratory	<u>N</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>S</u> Sludge Storage/Disposal	<u>N</u> Other
<u>S</u> Collection System		

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See attached letter.



Scott Foster, Inspector, Ohio EPA, Southeast District Office

9/19/08

Date



Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

9/19/08

Date