



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 8, 2008

Re: Monroe County
Ormet Primary Aluminum
Self-Monitoring Report Violations
Ohio EPA Permit #01E00005*LD
NPDES Permit #OH0011550
Correspondence (IWW)

Mr. John Reggi
Ormet Primary Aluminum
P.O. Box 176
Hannibal, Ohio 43931

Dear Mr. Reggi:

We have received your self-monitoring reports covering the months of April through June 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. Also, the violations for chlorine has placed your facility on the quarterly non-compliance list. The specific instances of noncompliance and/or deficiencies are as follows:

Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
April 2008	002	01119	Copper, Total Recoverable	1D Qty	0.025	.06991	4/7/2008
April 2008	004	50060	Chlorine, Total Residual	1D Conc	0.038	.073	4/7/2008
April 2008	004	50060	Chlorine, Total Residual	1D Conc	0.038	.13	4/11/2008
April 2008	002	50060	Chlorine, Total Residual	1D Conc	0.038	.05	4/14/2008
April 2008	002	01119	Copper, Total Recoverable	1D Qty	0.025	.12262	4/14/2008
April 2008	004	50060	Chlorine, Total Residual	1D Conc	0.038	.69	4/14/2008
April 2008	004	50060	Chlorine, Total Residual	1D Conc	0.038	.11	4/18/2008
April 2008	004	50060	Chlorine, Total Residual	1D Conc	0.038	.1	4/21/2008
April 2008	004	50060	Chlorine, Total Residual	1D Conc	0.038	.12	4/25/2008
April 2008	002	01119	Copper, Total Recoverable	1D Conc	36	36.6	4/28/2008
April 2008	002	01119	Copper, Total Recoverable	1D Qty	0.025	.08159	4/28/2008
April 2008	002	00718	Cyanide, Weakacid Diss	1D Conc	0.044	.048	4/28/2008
April 2008	002	00718	Cyanide, Weakacid Diss	1D Qty	0.031	.10701	4/28/2008
May 2008	002	50060	Chlorine, Total Residual	1D Conc	0.038	.098	5/5/2008


Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets and U.S. EPA's Facility Pollution Prevention Guide, (EPA/600/R-92/088), you may contact the Ohio EPA Pollution Prevention Section at (614) 644-3469 or me for additional information.

If there are any questions, please contact me at (740) 380-5227.

Sincerely,

A handwritten signature in black ink, appearing to read "Scott Foster", with a long horizontal flourish extending to the right.

Scott Foster
Environmental Specialist 2
Division of Surface Water

SF/dh