



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 6, 2009

**Re: Morgan County
Village of Stockport
Self-Monitoring Report Violations
Ohio EPA Permit No. OPA00005*JD
NPDES Permit No. OH0020249
Correspondence (PWW)**

Mr. Kevin Manning, Mayor
Village of Stockport
P.O. Box 158
Stockport, Ohio 43787

Dear Mr. Manning:

We have received your self-monitoring reports covering the months of January through March 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
January 2009	001	00530	Total Suspended Solids	30D Conc	30	53.6666	1/1/2009
January 2009	001	00530	Total Suspended Solids	30D Qty	10	15.5916	1/1/2009
January 2009	001	80082	CBOD 5 day	30D Conc	25	39.6666	1/1/2009
January 2009	001	80082	CBOD 5 day	30D Qty	8.5	11.5732	1/1/2009
January 2009	001	00530	Total Suspended Solids	7D Conc	45	75.	1/15/2009
January 2009	001	00530	Total Suspended Solids	7D Qty	15	22.1422	1/15/2009
January 2009	001	80082	CBOD 5 day	7D Conc	40	54.	1/15/2009
January 2009	001	80082	CBOD 5 day	7D Qty	13.6	15.9424	1/15/2009
February 2009	001	00530	Total Suspended Solids	30D Conc	30	49.	2/1/2009
February 2009	001	00530	Total Suspended Solids	7D Conc	45	56.	2/1/2009
February 2009	001	00530	Total Suspended Solids	30D Qty	10	14.0186	2/1/2009
February 2009	001	80082	CBOD 5 day	30D Conc	25	41.75	2/1/2009
February 2009	001	80082	CBOD 5 day	7D Conc	40	48.	2/1/2009
February 2009	001	80082	CBOD 5 day	30D Qty	8.5	11.5565	2/1/2009
February 2009	001	00530	Total Suspended Solids	7D Conc	45	55.	2/8/2009
February 2009	001	00530	Total Suspended Solids	7D Qty	15	23.1074	2/8/2009
February 2009	001	80082	CBOD 5 day	7D Qty	13.6	16.3852	2/8/2009
February 2009	001	00530	Total Suspended Solids	7D Conc	45	51.	2/22/2009
February 2009	001	80082	CBOD 5 day	7D Conc	40	42.	2/22/2009

Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
March 2009	001	00530	Total Suspended Solids	30D Conc	30	35.25	3/1/2009
March 2009	001	00530	Total Suspended Solids	7D Conc	45	47.	3/1/2009
March 2009	001	80082	CBOD 5 day	30D Conc	25	38.75	3/1/2009
March 2009	001	80082	CBOD 5 day	7D Conc	40	54.	3/1/2009
March 2009	001	00530	Total Suspended Solids	7D Conc	45	50.	3/22/2009


Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets and U.S. EPA's Facility Pollution Prevention Guide, (EPA/600/R-92/088), you may contact the Ohio EPA Pollution Prevention Section at (614) 644-3469 or me for additional information.

If there are any questions, please contact me at (740) 380-5227.

Sincerely,



Scott Foster
Environmental Specialist 2
Division of Surface Water

SF/dh