



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

October 3, 2007

**Re:** Morgan County  
Burr Oak Lodge and Cabins  
0PP00002\*ED  
CEI 2008  
Correspondence (PWW)

Mr. Eric Compston, Operator  
Burr Oak Lodge and Cabins Wastewater Treatment  
10660 Burr Oak Lodge Road  
Glouster, Ohio 45732

Dear Mr. Compston:

On September 11, 2007 I conducted a Compliance Evaluation Inspection at the Burr Oak Lodge and Cabins WWTP. I was accompanied by you. The following are comments from the inspection:


1. The line from the pump station to the sand filters has a leak in it and should be repaired immediately. This is an illegal bypass of the treatment system.
2. The chlorine feed system was broken. You had chlorine tablets lying in the weir boxes of the final tank. This is not an acceptable practice for disinfection. You cannot control the rate of chlorine feed and it is a waste of chemicals. Please repair the disinfection system immediately to comply with your NPDES permit. This facility has had numerous chlorine violations in the past year.
3. For your Monthly Operating Reports, please report the code "AL" for outfall 002 and submit an MOR for it monthly. Until the new facility is built, there will not be a discharge or information to report. This will allow Ohio EPA to keep the current permit issued and allow for future reporting of the new facility.

After talking with you, I contacted Tara Lee of ODNR's Engineering Division and she informed me that the wastewater project for Burr Oak is funded and scheduled to be completed in the near future.

Due to the problems at the facility, I rate it as marginal. Please respond to this letter within 30 days of receipt.

If you have any questions or comments, please feel free to contact me at (740) 380-5227.

Sincerely,

A handwritten signature in black ink, appearing to read "Scott Foster", with a long horizontal flourish extending to the right.

Scott Foster  
Environmental Specialist 2  
Division of Surface Water

SF/dh

Enclosure

- c: Tara Lee, ODNR
- c: Chris Hardman, Park Manager, Burr Oak State Park
- c: Greg Masterson

**NPDES**  
Compliance Inspection Report

**A. NATIONAL DATA SYSTEM CODING**

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPP00002*ED	OH0036137	September 11, 2007	C	S	1

**B. FACILITY DATA**

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Ohio Department of Natural Resources Burr Oak State Park, Lodge and Cabins WWTP 10660 Burr Oak Lodge Road Glouster, Ohio 45732	11:00 a.m.	March 1, 2007
	Exit Time	Permit Expiration Date
	11:15 a.m.	February 29, 2012

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Eric Compston, Operator	(740) 767-4915
Name, Address and Title of Responsible Official	Phone Number
Chris Hardman, Park Manager 10660 Burr Oak Lodge Road Glouster, Ohio 45732	(740) 767-3570


**C. AREAS EVALUATED DURING INSPECTION**

<u>  </u> S Permit	<u>  </u> S Flow Measurement	<u>  </u> N Pretreatment
<u>  </u> S Records/Reports	<u>  </u> S Laboratory	<u>  </u> S Compliance Schedules
<u>  </u> M Operations & Maintenance	<u>  </u> S Effluent/Receiving Waters	<u>  </u> S Self-Monitoring Program
<u>  </u> M Facility Site Review	<u>  </u> N Sludge Storage/Disposal	<u>  </u> N Other
<u>  </u> N Collection System		

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

**D. SUMMARY OF FINDINGS/COMMENTS** (attach additional sheets if necessary)

See attached letter.

  
\_\_\_\_\_  
Scott Foster, Inspector, Ohio EPA, Southeast District Office

10/2/07  
\_\_\_\_\_  
Date

  
\_\_\_\_\_  
Timothy M. Campbell, Rewewer, Ohio EPA, Southeast District Office

10/2/07  
\_\_\_\_\_  
Date