



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

April 21, 2009

**Re: Morgan County
Altier Elementary School
CEI-2009
Correspondence (PWW)**

Ms. Lori Snyder-Lowe, Assistant Superintendent
Morgan Local Schools
820 Riverside Drive South
McConnelsville, Ohio 43756-9101

Dear Ms. Snyder-Lowe:

On March 3, 2009, I conducted a Compliance Evaluation Inspection for the Altier Elementary School. I was accompanied by David Work, Contract Operator; and Mike Newcome, Head of Maintenance. The inspection was conducted to check the school's compliance with its NPDES permit. The following are comments from the inspection:

We discussed ammonia problems with the treatment facility. I suggested that an air line be installed into the trash tank to enhance ammonia removal. If there would be a problem with the addition of the air not allowing solids to settle properly, the practice should be discontinued.

We discussed the hardship of running the facility in the summer months when there is virtually no flow. I had mentioned the possibility of using the facility as a holding tank and keeping it pumped out periodically until school starts back up in the fall.

We also discussed the proper procedures for disposal of hazardous waste from the school. The operators mentioned to me that they had the plant's biological processes damaged by different substances being discharged to the facility. I mentioned to them that our Division of Hazardous Waste Management could assist them in setting up a program of proper disposal at the school.

If you have any questions or comments, please feel free to call me at (740) 380-5227.

Sincerely,

Scott Foster
Environmental Specialist 2
Division of Surface Water

SF/dh

Enclosure

c: David Work, Operator
c: Mike Newcome, Head of Maintenance

**NPDES
Compliance Inspection Report**

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPT00057*BD	OH0127914	March 3, 2009	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Altier Elementary School WWTP 9675 West State Route 37 Malta, Ohio 43758	10:20 AM	March 1, 2007
	Exit Time	Permit Expiration Date
	10:35 AM	February 29, 2012

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
David Work, Contract Operator	740-962-3163
Mike Newcome, Head of Maintenance	740-541-1263
Name, Address and Title of Responsible Official	Phone Number
Lori-Snydar-Lowe, Asst. Superintendent 820 Riverside Drive South McConneville, Ohio 43756-9101	740-962-3239


C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>S</u> Flow Measurement	<u>N/A</u> Pretreatment
<u>S</u> Records/Reports	<u>N/A</u> Laboratory	<u>N/A</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>S</u> Sludge Storage/Disposal	<u>N/A</u> Other
<u>N/A</u> Collection System		

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See Attached Letter.



 Scott Foster, Inspector, Ohio EPA, Southeast District Office

4/21/09

 Date



 Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

4/21/09

 Date