



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 19, 2010

**Re: Muskingum County
Westgate Terrace MHP
Self-Monitoring Report Violations
Ohio EPA Permit #0PV00016*BD
NPDES Permit #OH0115410
Correspondence (PWW)**

Mr. David L. Cook, Owner
Westgate Terrace MHP
1826 South Main Street
Akron, Ohio 44301

Dear Mr. Cook:

We have received your self-monitoring reports covering the months of July through December 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
August 2009	001	Nitrogen, Ammonia (NH3)	30D Conc	1.0	2.289	8/1/2009
August 2009	001	Nitrogen, Ammonia (NH3)	30D Qty	0.032	.04446	8/1/2009
August 2009	001	CBOD 5 day	30D Conc	10	13.5	8/1/2009
August 2009	001	Nitrogen, Ammonia (NH3)	7D Conc	1.5	4.1	8/8/2009
August 2009	001	Nitrogen, Ammonia (NH3)	7D Qty	0.048	.08473	8/8/2009
August 2009	001	CBOD 5 day	7D Conc	12	20.	8/8/2009
August 2009	001	CBOD 5 day	7D Qty	0.38	.41332	8/8/2009
December 2009	001	Nitrogen, Ammonia (NH3)	30D Qty	0.127	.13904	12/1/2009
December 2009	001	CBOD 5 day	30D Conc	10	17.	12/1/2009
December 2009	001	CBOD 5 day	30D Qty	0.32	.68913	12/1/2009
December 2009	001	CBOD 5 day	7D Conc	12	17.	12/8/2009
December 2009	001	CBOD 5 day	7D Qty	0.38	.68913	12/8/2009

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets and U.S. EPA's Facility Pollution Prevention Guide, (EPA/600/R-92/088), you may contact the Ohio EPA Pollution Prevention Section at (614) 644-3469 or me for additional information.

If there are any questions, please contact me at (740) 380-5227.

Sincerely,



Scott Foster
Environmental Specialist 2
Division of Surface Water

SF/dh