



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

November 19, 2009

**Re: Muskingum County  
Wild Bill's Campground  
CEI 2010  
Correspondence (PWW)**

Mr. William C. Boys, Campground Operator  
Wild Bill's Campground  
6819 Newark Road  
Nashport, Ohio 43830

Dear Mr. Boys:

On September 4, 2009, I conducted a Compliance Evaluation Inspection for Wild Bills Campground wastewater treatment plant with Mr. Mike Wisecarver. I had previously visited the site with Mr. Tim Campbell of Ohio EPA on August 31, 2009. The following are the deficiencies with the plant that we found upon our site visit:


- The equalization tank pumps were not operational.
- Half of the plant was not operational.
- The upflow clarifier pumps were not operational and the upflow was full of sludge.
- The skimmer was not operational.
- Sludge was on the ground indicating an overflow of the system.
- The sand filters were clogged and holding water.
- There were no dechlorination tablets in the feeder.

At our meeting on September 9, 2009 at the Southeast District Office of the Ohio EPA, we discussed the condition of the plant and gave you a time frame to make improvements to the facility and the collection system. We originally gave you a deadline of October 31, 2009, but extended it to November 4, 2009, to allow for camera work to be completed on the collection system. Please provide a written update on the progress of the maintenance actions to date and a report of the condition of the collection system found by the camera crew and future plans to fix the system by November 30, 2009. If you fail to provide further information or comply with Part III, Section 3 of your NPDES permit, we will be forced to take formal enforcement action.

Due to the above-mentioned maintenance problems, I rate the facility as unsatisfactory.  
Please respond by November 30, 2009.

If you have any additional questions or comments, please feel free to call at (740) 380-5227.

Sincerely,

A handwritten signature in black ink, appearing to read "Scott Foster", with a long horizontal line extending to the right.

Scott Foster  
Environmental Specialist 2  
Division of Surface Water

SF/dh

Enclosure

c: Mike Wisecarver, Wisecarver Environmental

**NPDES**  
Compliance Inspection Report

**A. NATIONAL DATA SYSTEM CODING**

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0PR00101*CD	OH0104213	September 4, 2009	C	S	1

**B. FACILITY DATA**

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Wild Bill's Campground 6819 Newark Road Nashport, Ohio 43830	9:00 a.m.	August 1, 2006
	Exit Time	Permit Expiration Date
	11:00 a.m.	July 31, 2011

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
William C. Boys, Campground Operator	(740) 452-0113
Name, Address and Title of Responsible Official	Phone Number
William C. Boys, Campground Operator 6819 Newark Road Nashport, Ohio 43830	(740) 452-0113

**C. AREAS EVALUATED DURING INSPECTION**

<u>  </u> S Permit	<u>  </u> S Flow Measurement	<u>  </u> N Pretreatment
<u>  </u> S Records/Reports	<u>  </u> N Laboratory	<u>  </u> N/A Compliance Schedules
<u>  </u> U Operations & Maintenance	<u>  </u> U Effluent/Receiving Waters	<u>  </u> U Self-Monitoring Program
<u>  </u> U Facility Site Review	<u>  </u> U Sludge Storage/Disposal	<u>  </u> N/A Other
<u>  </u> U Collection System		

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

**D. SUMMARY OF FINDINGS/COMMENTS** (attach additional sheets if necessary)

See attached letter.

  
\_\_\_\_\_  
Scott E. Foster, Inspector, Ohio EPA, Southeast District Office

11/19/09  
\_\_\_\_\_  
Date

  
\_\_\_\_\_  
Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

11/19/09  
\_\_\_\_\_  
Date