



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Scott J. Nally, Director

November 14, 2012

Mr. Steven Durall
 Bethel Local School District
 7490 S. State Route 201
 Tipp City, OH 45371

RE: Miami County, Bethel Local School District WWTP, NPDES Permit Violations

Dear Mr. Durall:

Ohio EPA has completed a review of the Discharge Monitoring Reports covering the months of January through September 2012 for the above referenced facility. The evaluation indicates violations of the conditions of your NPDES permit (NPDES Permit #OH0133876; Ohio EPA #1PT00114*CD). The specific instances of noncompliance for the above mentioned review period are as follows:

Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
January 2012	Ammonia	Monthly	mg/l	3.0	10.4
January 2012	Ammonia	Monthly	kg/d	0.3	0.7
February 2012	Ammonia	Monthly	mg/l	3.0	25.0
February 2012	Ammonia	Monthly	kg/d	0.3	0.8
February 2012	CBOD ₅	Monthly	mg/l	10.0	15.0
March 2012	Ammonia	Monthly	mg/l	3.0	14.5

Please inform this office, in writing, by December 7, 2012, as to the reason for the above referenced violations, as well as a description of the actions taken or proposed to prevent further violations.

Please be advised that failure to comply with the effluent limits, monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code 6111.

Mr. Steven Durall
Bethel Local School District
November 14, 2012
Page 2

If you have any questions or concerns regarding this matter, please feel free to contact at (937) 285.6033 or via email glen.vonderembse@epa.ohio.gov.

Sincerely,

A handwritten signature in black ink, consisting of several loops and a long horizontal stroke extending to the right.

Glen Vonderembse
Environmental Engineer
Division of Surface Water

GV/tf