



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Kortleski, Director

July 10, 2008

Re: Muskingum County
Philo Junior High School
Self-Monitoring Report Violations
Ohio EPA Permit #OPT00044
NPDES Permit #OH0124753
Correspondence (PWW)

Mr. Robert Walden, Assistant Supt.
Franklin Local School District
360 Cedar Street
Duncan Falls, Ohio 43734

Dear Mr. Walden:

We have received your self-monitoring reports covering the months of October 2007 through March 2008 for the Philo Junior High School. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Report Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
Oct 2007	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	10.5	10/1/07
Oct 2007	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.04	.20797	10/1/07
Oct 2007	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	1.5	10.5	10/22/07
Oct 2007	001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.05	.20797	10/22/07
Nov 2007	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	14.3	11/1/07
Nov 2007	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.11	.1259	11/1/07
Nov 2007	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	4.5	14.3	11/8/07
Dec 2007	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	35.	12/1/07
Dec 2007	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.11	.53931	12/1/07
Dec 2007	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	4.5	35.	12/15/07
Dec 2007	001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.16	.53931	12/15/07
Jan 2008	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	24.	1/1/08
Jan 2008	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.11	.36981	1/1/08
Jan 2008	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	4.5	24.	1/8/08
Jan 2008	001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.16	.36981	1/8/08
Feb 2008	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	26.	2/1/08
Feb 2008	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	4.5	26.	2/1/08
Feb 2008	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.11	.62943	2/1/08
Feb 2008	001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.16	.62943	2/1/08


Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets and U.S. EPA's Facility Pollution Prevention Guide, (EPA/600/R-92/088), you may contact the Ohio EPA Pollution Prevention Section at (614) 644-3469 or me for additional information.

If there are any questions, please contact me at (740) 380-5227.

Sincerely,



Scott Foster
Environmental Specialist 2
Division of Surface Water

SF/dh