



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 18, 2007

Re: Muskingum County
Riverview Manor MHP & Apt.
CEI- 2008
Correspondence (PWW)

Mr. Keith Shrider, Owner
Riverview Manor MHP & Apt.
P.O. Box 2041
Zanesville, Ohio 43702

Dear Mr. Shrider:

On November 15, 2007, I conducted a Compliance Evaluation Inspection for the Riverview Manor MHP & Apt Wastewater Facility. The following are comments from the inspection:

1. The tank had visible floating sludge on it and a sludge blanket was noticeable inside the tank. This was a good indication of poor sludge wasting practices and the neglect of maintenance at the facility. Please provide regular maintenance to the wastewater facility and regular wasting of solids. I have enclosed a photo taken the day of the inspection that shows the sludge blanket on the tank.

Because of the condition of the facility, I rated several areas as marginal on the attached inspection report.

If you have any questions or comments, please feel free to call me at (740) 380-5227.

Sincerely,

Scott Foster
Environmental Specialist 2
Division of Surface Water

SF/dh

Enclosure

c: Mike Wisecarver, Operator

**NPDES
Compliance Inspection Report**

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0PV00029*BD	OH0127647	November 15, 2007	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Riverview Manor MHP & Apt 1710 South River Road Zanesville, Ohio 43701	12:30 pm	August 1, 2006
	Exit Time	Permit Expiration Date
	12:45 pm	July 31, 2011

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Mike Wisecarver, Operator	740-453-1716
Name, Address and Title of Responsible Official	Phone Number
Keith Shrider, Owner PO Box 2041 Zanesville, Ohio 43702	740-453-5552


C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>S</u> Flow Measurement	<u>N/A</u> Pretreatment
<u>S</u> Records/Reports	<u>S</u> Laboratory	<u>N/A</u> Compliance Schedules
<u>M</u> Operations & Maintenance	<u>M</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>M</u> Facility Site Review	<u>S</u> Sludge Storage/Disposal	<u>N</u> Other
<u>N</u> Collection System		

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See Attached Letter.



Scott Foster, Inspector, Ohio EPA, Southeast District Office

12/19/07

Date



Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

12/19/07

Date

