



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 2, 2008

Re: Muskingum County
The Longaberger Company
Self-Monitoring Report Violations
Ohio EPA Permit #01M00018
NPDES Permit #OH0107786
Correspondence (IWW)

Ms. MaryAnn Figgins, Env. Affairs Coordinator
The Longaberger Company
5565 Raiders Road
Frazeyburg, Ohio 43822

Dear Ms. Figgins:

We have received your self-monitoring reports covering the months of October 2007 and March 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

| Report Period | Station | Reporting Code | Parameter | Limit Type | Limit | Reported Value | Violation Date |
|---------------|---------|----------------|-------------------------|------------|-------|----------------|----------------|
| Jan 2008 | 001 | 00530 | Total Suspended Solids | 1D Conc | 18.0 | 19. | 1/22/08 |
| Jan 2008 | 001 | 00530 | Total Suspended Solids | 1D Conc | 18.0 | 37. | 1/31/08 |
| Feb 2008 | 001 | 00530 | Total Suspended Solids | 30D Conc | 12.0 | 18.75 | 2/1/08 |
| Feb 2008 | 001 | 00530 | Total Suspended Solids | 1D Conc | 18.0 | 38. | 2/7/08 |
| Feb 2008 | 001 | 00530 | Total Suspended Solids | 1D Conc | 18.0 | 39. | 2/19/08 |
| Mar 2008 | 001 | 00530 | Total Suspended Solids | 1D Conc | 18.0 | 23. | 3/4/08 |
| Oct 2007 | 001 | 00610 | Nitrogen, Ammonia (NH3) | 30D Conc | 2.0 | 3.3702 | 10/1/07 |
| Oct 2007 | 001 | 00610 | Nitrogen, Ammonia (NH3) | 1D Qty | 2.27 | 3.1794 | 10/30/07 |
| Oct 2007 | 001 | 00610 | Nitrogen, Ammonia (NH3) | 1D Conc | 3.0 | 14. | 10/30/07 |
| Feb 2008 | 001 | 80082 | CBOD 5 day | 30D Conc | 10.0 | 11.7142 | 2/1/08 |
| Feb 2008 | 001 | 80082 | CBOD 5 day | 1D Conc | 15.0 | 16. | 2/21/08 |
| Feb 2008 | 001 | 80082 | CBOD 5 day | 1D Conc | 15.0 | 22. | 2/28/08 |

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets and U.S. EPA's Facility Pollution Prevention Guide, (EPA/600/R-92/088), you may contact the Ohio EPA Pollution Prevention Section at (614) 644-3469 or me for additional information.

If there are any questions, please contact me at (740) 380-5227.

Sincerely,



Scott Foster
Environmental Specialist 2
Division of Surface Water

SF/dh