

**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 18, 2011

Re: Tuscarawas County
Wood's Tall Timber Lake Resort
Reconnaissance Inspection
Correspondence (PWW)

Mr. Larry Wood
Wood's Tall Timber Lake Resort
156 Waldenmyer Drive
Dover, Ohio 44622


Dear Mr. Wood:

On May 12, 2011, I conducted a reconnaissance inspection at the Wood's Tall Timber Lake Resort. The purpose of the inspection was to determine compliance with the terms and conditions of National Pollutant Discharge Elimination System (NPDES) Permit Number OPR00155*AD and to evaluate wastewater treatment plant performance. At the time of my inspection, I determined that the wastewater treatment plant has not been constructed to date. Currently, the temporary sewage holding tanks along with the septic tanks and leach field were still in operation. The contents of the holding tanks and septic tanks are pumped on a regular basis and hauled to the New Philadelphia wastewater treatment plant for disposal.

A review of your file reveals a time extension for Permit to Install application No. 658643 was issued on August 17, 2010. You have until August 24, 2011 to initiate construction of the new wastewater treatment plant. I understand you plan to initiate construction in July. Please be aware your Permit to Install requires you to notify the Southeast District Office of the Ohio Environmental Protection Agency in writing of (a) the construction starting date; (b) the construction completion date; and (c) the date the wastewater disposal system was placed into operation. In addition, the permit requires before the applicant generates any wastewater or discharges any wastewater to the disposal system, the construction of the wastewater treatment works shall be completed, and the treatment works operation must be authorized by the Ohio EPA district office.

A copy of our completed inspection report is enclosed. Please submit a written response to the aforementioned comments within thirty (30) days of receipt of this letter. The assistance and cooperation received during the inspection are appreciated. If you have any questions, please contact me at (740) 380-5206.

Sincerely,



Jennifer M. Witte
Chemical Engineer – Environmental Specialist II
Division of Surface Water

JMW/dh

Enclosure

NPDES

Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPR00155*AD	OH0139769	May 12, 2011	R	S	1

B. FACILITY DATA

Name & Location of Facility Inspected	Entry Time	Permit Effective Date
Wood's Tall Timber Lake Resort 1921 Tall Timber Road, NE New Philadelphia, Ohio 44663	11:00 a.m.	April 1, 2009
	Exit Time	Permit Expiration Date
	12:30 p.m.	March 31, 2014

Name(s) & Title(s) of On-Site Representative(s)	Phone Number(s)
Larry Wood, Owner	(330) 339-7002
Name, Address, & Title of Responsible Official	Phone Number
Larry Wood, Owner 156 Waldenmyer Drive Dover, Ohio 44622	(330) 339-7002


C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>N/A</u> Flow Measurement	<u>N/A</u> Pretreatment
<u>S</u> Records/Reports	<u>N/A</u> Laboratory	<u>N/A</u> Compliance Schedules
<u>M</u> Operations & Maintenance	<u>N/A</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>N/A</u> Sludge Storage/Disposal	<u> </u> Other
<u>S</u> Collection System		

(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated; N/A = Not Applicable)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See attached letter.


 Jennifer M. Witte, Inspector, Ohio EPA, Southeast District Office

7/21/11
 Date


 Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

7/21/11
 Date