



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 24, 2007

Re: Tuscarawas County
General Electric
Notice of Violation
OIS00010, OH0041572
Correspondence (IWW)

Mr. Scott F. Carbaugh, Plant Manager
General Electric Consumer & Industrial
Dover Products Plant
200 West Broadway
Dover, Ohio 44662

Dear Mr. Carbaugh:

We have received your self-monitoring reports covering the months of August 2006 through August 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Outfall	Date	Parameter	Reported	Units	Permit Limitation
November 2006:					
001	11/15-11/28	pH	None	S.U.	Monitoring required ½ weeks
001	11/15-11/28	Water Temperature	None	°C	Monitoring required ½ weeks
001	11/29	pH	6.4	S.U.	6.5 minimum
July 2007:					
001	7/1-7/14	pH	None	S.U.	Monitoring required ½ weeks
001	7/1-7/14	Water Temperature	None	°C	Monitoring required ½ weeks

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,

Jennifer M. Witte
Chemical Engineer - Environmental Specialist 2
Division of Surface Water

JMW/dh