



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

May 19, 2010

**Re:** Vinton County  
M & S Manufacturing  
Buckeye Automatic Division  
Compliance Inspection  
NPDES Permit 0IS00020\*DD  
Correspondence (IWW)

Mr. Harold Hammond  
P.O. Box 479  
McArthur, Ohio 45651

Dear Mr. Hammond:

On May 4, 2010, I conducted a compliance inspection of M&S Manufacturing Buckeye Automatic Division. Rick Vesholtz accompanied me with the inspection of the facility. The purpose of the inspection was to determine compliance with the terms and conditions of National Pollutant Discharge Elimination System (NPDES) Permit Number 0IS00020\*DD. Results of the inspection are summarized below.

At the time of the inspection, the plant was in good condition. The liquid in the aeration basin was light in color, most likely from the low flows in this facility. The newer dechlorination tank was properly installed. The effluent appeared to be clear.

If you have any questions, please contact me at (740) 380-5266.

Sincerely,

Cynthia Yandrich  
District Representative  
Division of Surface Water

CY/dh

Enclosure

**NPDES**  
Compliance Inspection Report

**A. NATIONAL DATA SYSTEM CODING**

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0IS00020*DD	OH0094919	May 4, 2010	C	S	2

**B. FACILITY DATA**

Name & Location of Facility Inspected	Entry Time	Permit Effective Date
M & S Manufacturing, Buckeye Automatic Division 33645 State Route 93 McArthur, Ohio, Vinton County	9:25 a.m.	August 1, 2006
	Exit Time	Permit Expiration Date
	9:45 a.m.	July 31, 2011

Name(s) & Title(s) of On-Site Representative(s)	Phone Number(s)
Rick Vesholtz, Wastewater Operator	(740) 384-1363
Name, Address, & Title of Responsible Official	Phone Number
Harold Hammond, Operation Manager 33645 State Route 93 McArthur, Ohio, Vinton County	(740) 596-5245

**C. AREAS EVALUATED DURING INSPECTION**

<u>S</u> Permit	<u>S</u> Flow Measurement	<u>N/A</u> Pretreatment
<u>S</u> Records/Reports	<u>N</u> Laboratory	<u>N/A</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>N</u> Sludge Storage/Disposal	<u>    </u> Other
<u>N</u> Collection System		

(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated; N/A = Not Applicable)

**D. SUMMARY OF FINDINGS/COMMENTS** (attach additional sheets if necessary)

See attached letter.

  
Cynthia Yandrich, Inspector, Ohio EPA, Southeast District Office

5-18-10  
Date

  
Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

5/19/10  
Date