



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



February 20, 2013

Ms. Serena Raybould  
Taverne of Richfield  
3960 Broadview Road  
Richfield, OH 44286

Summit County  
Taverne Of Richfield  
Non-Community, Transient PWS  
PWS ID: OH7769412  
**VIO ID: 8573524**

**Subject: Rescinding Violation – TCR**

Dear Ms. Raybould:

Your public water system was issued a notice of violation of Rule 3745-81-21 of the Ohio Administrative Code (OAC) on 1/22/2013 for the monitoring period of 4Q2012. The sample was collected on 10/5/2012, but the result was not reported until 2/12/2012.

The violation has been rescinded and the public notice sent with the notice of violation referenced above does not need to be issued at this time.

OAC 3745-81-31 and 3745-89-08 require results to be reported by the tenth day following the month the sample was collected. Further, OAC 3745-89-08 requires the laboratory to report all positive, all repeat sample results and all samples required by OAC 3745-81-42 (Ground Water Rule) no later than the end of the next business day after the result was obtained. The samples were not reported in accordance with the above rules, and this is considered a reporting violation.

Please ensure future sample results are submitted as required. If you have any questions, please contact this office at 330-963-1227.

Sincerely,

Ursula Musselman  
Environmental Specialist  
Division of Drinking and Ground Waters

UM:ds

cc: Summit County Health Department  
Eastern Lab  
District Office File