



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

February 12, 2013

Commander Bruce Johnson
15813 SR 36 E
Laurelville, OH 43135

Pickaway County
Laurelville VFW Post 8657
Transient Non-Community
Water System
PWS ID OH6540012

Dear Commander Johnson:

The Public Water System serving LAURELVILLE VFW 8657 PWS is in violation of the Ohio Administrative Code (OAC) for:

Failure to respond in Writing within 30 days

This letter is notification that the Laurelville VFW Post 8657 public water system has not complied with requirements issued during this Agency's last survey performed on December 21, 2012, in violation of rule 3745-81-60 of the Ohio Administrative Code. The PWS was notified in correspondence dated December 31, 2012, to respond in writing no later than 30 days, with a time frame for:

1. Verifying the old abandoned well (near the existing well) is filled with bentonite material by sending a copy of the ODNR well seal report to this office. The casing should be cut off near floor level.

Please respond in writing within 15 days of the date of this letter with a time frame for complying with the requirement above. If you have any questions please call your Ohio EPA representative at (614) 728-3864.

Sincerely,

Carolyn O'Neal
Environmental Specialist III
Division of Drinking and Ground Waters
Central District Office

ec: CDO DDAGW AA (State Violation)
CDO File

CO/ct 6540012(FR)SanitarySurveyJAN2013