



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

March 1, 2013

Mr. John Horman
ODOT Rest Area 7-26
1001 St. Marys Avenue
Sidney, Ohio 45365

Auglaize County
ODOT Rest Area 7-26
Transient Non-Community PWS
PWS ID: OH0632412

Dear Mr. Horman:

ODOT Rest Area 7-26 is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-83-01 (C)(1), the public water system failed to maintain the minimum required (free/combined) chlorine residual in the distribution system when the residual disinfectant concentration of the drinking water at representative points throughout the distribution systems was less than (two-tenths milligram per liter free chlorine / one milligram per liter combined chlorine). There were six days during January, 2013 in which the minimum chlorine residual was not maintained.

ODOT Rest Area 7-26 must take immediate action to resolve this violation. Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action. Your response to this letter is required by March 29, 2013.

If you have any questions, please contact me at (419) 373-3007 or by e-mail at clayton.mckee@epa.ohio.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "Clayton McKee".

Clayton McKee
Division of Drinking and Ground Waters

/cg

pc: Allen County Health Department
DDAGW – NWDO

