



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



February 21, 2013

**NOTICE OF VIOLATION – ACTION REQUIRED**

Mr. Joseph F. Badalamenti

Pleasant Acres Mobile Community LLC  
44140 Riverview Ridge  
Clinton Township, Michigan 48038

Marion County  
Pleasant Acres Mobile Home  
Community LLC  
Community PWS

PWS ID: OH5100612

Dear Mr. Badalamenti:

The Public Water System serving Pleasant Acres Mobile Home Community LLC is in violation of the Ohio Administrative Code (OAC) for failure to comply with the operational requirements of OAC 3745-83-01 during the following months.

In violation of OAC 3745-83-01(H)(1)(c), the public water system failed on at least four days to report plant production for the following months: August 2011; September 2011; November 2011; December 2011; May 2012; June 2012; July 2012; August 2012; November 2012; and December 2012.

In violation of OAC 3745-83-01(F)(9)(a), the public water system failed to report hardness at the plant tap on a monthly basis. No analysis was reported for the following months: August 2011; September 2011; October 2011; January 2012; February 2012; March 2012; April 2012; May 2012; June 2012; July 2012; August 2012; September 2012; October 2012; November 2012; and December 2012.

In violation of OAC 3745-83-01 (F)(2), the public water system failed to report free or combined chlorine residual daily at the plant tap. There were 29 days during February 2012, in which the analysis was not performed.

If you have any questions, please contact me at (419) 373-3108 or by e-mail at [janis.damico@epa.ohio.gov](mailto:janis.damico@epa.ohio.gov).

Sincerely,

Janis D'Amico  
Division of Drinking and Ground Waters

/llr

pc: DDAGW – NWDO

