



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

March 1, 2013

Mr. Mike Leis
Beaverdam Water Treatment Plant
101 West Main Street
Beaverdam, Ohio 45808

Allen County
Beaverdam Water Treatment Plant
Community PWS
PWS ID: OH0200012

Dear Mr. Leis:

Beaverdam Water Treatment Plant is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for manganese which is 0.05 mg/L. There were four weeks during January, 2013 in which manganese exceeded the secondary standard.

Violation of the secondary standard for manganese does not require public notification. Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.

Beaverdam Water Treatment Plant must take immediate action to resolve this/these violation(s). Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action. Your response to this letter is required by March 29, 2013.

If you have any questions, please contact me at (419) 373-3007 or by e-mail at clayton.mckee@epa.ohio.gov.

Sincerely,

Clayton McKee
Division of Drinking and Ground Waters

/cg

pc: Allen County Health Department
DDAGW – NWDO

