



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



March 1, 2013

Mr. David Danhoff
Lakota Pre K-12 School
5200 County Road 13
Kansas, Ohio 44841

Sandusky County
Lakota Pre K-12 School
Non-Transient Non-Community PWS
PWS ID: OH7259312
VIO ID: 1

Subject: Rescinding Violation – TCR

Your public water system was issued a notice of violation of Rule 3745-81-21 of the Ohio Administrative Code (OAC) dated February 26, 2013 for the monitoring period of January 2013. The samples were both collected on January 2, 2013, but one of the results was reported to our office as being collected on January 2, 2012. The laboratory contacted our office and had the incorrect sample result resubmitted with the correct year.

The violation has been rescinded and the public notice sent with the notice of violation referenced above does not need to be issued at this time.

OAC 3745-81-31 and 3745-89-08 require results to be reported by the tenth day following the month the sample was collected. Further, OAC 3745-89-08 requires the laboratory to report all positive, all repeat sample results and all samples required by OAC 3745-81-42 (Ground Water Rule) no later than the end of the next business day after the result was obtained. The samples were not reported in accordance with the above rules and this is considered a reporting violation.

Please ensure future sample results are submitted as required. If you have any questions, please contact this office at 419-373-3089 or by e-mail at jill.schiefer@epa.ohio.gov.

Sincerely,

Jill A. Schiefer
Division of Drinking and Ground Waters

/cg

pc: Sandusky County Health Department
Alloway Marion Laboratory
DDAGW - NWDO

