




Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



December 28, 2011

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. Trent Rothert
1084 South Opfer-Lentz Road,
Elmore, Ohio 43416

Ottawa County
Rothert Amlc
TRANSIENT NON-COMMUNITY PWS
PWS ID: OH6237012

Dear Mr. Rothert:

The Public Water System serving ROTHERT AMLC is in violation of the Ohio Administrative Code (OAC) for:

Failure to respond in Writing within 30 days

This letter is notification that the Rothert AMLC public water system has not complied with requirements issued during this Agency's last survey performed on October 5, 2011, in violation of rule 3745-81-60 of the Ohio Administrative Code. The PWS was notified in correspondence dated October 18, 2011, to respond in writing no later than 30 days, with time frames for:

1. The electrical conduit connection on the well cap isn't sealed. The connection on the well cap must be threaded and sealed to prevent the entrance of insects and water [OAC Rule 3745-9-05(P)]
2. Prepare a bacteria sample siting plan and forward a copy to the Ohio EPA Northwest Office [OAC Rule 3745-81-21(A)].

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

If you have any questions, please contact me at 419-373-3107 or Elizabeth.Ames@epa.state.oh.us.

Sincerely,

Elizabeth Ames
Environmental Specialist 2
Division of Drinking and Ground Waters

/l/r

pc: Mary Clifton, ODH
DDAGW-NWDO File
ec: DDAGW-NWDO AA (State Violation)

