



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



**NOTICE OF VIOLATION – ACTION REQUIRED**

March 11, 2013

Ms. Ann Nightingale  
Village Green MHP  
7630 Reitz Road-Office  
Perrysburg, Ohio 43551

Wood County  
Village Green MHP  
Community PWS  
PWS ID: OH8702412

Dear Ms. Nightingale:

Village Green MHP – STU #1 is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-83-01 (F)(2), the public water system failed to report free or combined chlorine residual daily at the plant tap. There were 13 days during the month in which the analysis was not performed.

Village Green MHP must take immediate action to resolve this/these violation(s). Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action. Your response to this letter is required by April 8, 2013.

If you have any questions, please contact me at (419) 373-3108 or by e-mail at [janis.damico@epa.state.oh.us](mailto:janis.damico@epa.state.oh.us).

Sincerely,

A handwritten signature in cursive script that reads "Janis D'Amico".

Janis D'Amico  
Division of Drinking and Ground Waters

/cg

pc: Wood County Health Department  
DDAGW – NWDO

ec: Ohio Manufactured Homes Commission