




John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

March 8, 2013

Mr. Paul L. Wilkins
Apollo Mobile Home Park
9524 West Bloom Road
Oak Harbor, Ohio 43449

Sandusky County
Apollo Mobile Home Park
Community PWS
PWS ID: OH7200012

Dear Mr. Wilkins:

Apollo Mobile Home Park is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-81-70 (E)(1), the public water system failed to report the average value of all total chlorine residual analysis that were to be performed concurrently with the collection of total coliform bacterial samples in the month.

Failure to monitor the distribution system for chlorine residuals requires a tier 3 public notification per OAC 3745-81-32 (D). Public notice must be accomplished within one year for community systems; non-community systems must public notify within 30 days. An example public notice is enclosed for your reference. A verification form, attesting to the issuance of the public notice, is also enclosed. A copy of the public notice along with the verification form needs to be returned to this office within the timeframes cited earlier. If a community system wishes to provide public notice via the consumer confidence report then please contact this office for additional instruction.

Apollo Mobile Home Park must take immediate action to resolve this/these violation(s). Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action. Your response to this letter is required by April 8, 2013.

If you have any questions, please contact me at (419) 373-3108 or by e-mail at janis.damico@epa.ohio.gov.

Sincerely,

Janis D'Amico
Janis D'Amico
Division of Drinking and Ground Waters

/cg

Enclosure

pc: Sandusky County Health Department
DDAGW – NWDO (W/ enclosures)
ec: Ohio Manufactured Homes Commission

DRINKING WATER NOTICE

Monitoring requirements not met for Apollo Mobile Home Park

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During January 2013 we did not monitor for total chlorine and therefore cannot be sure of the quality of our drinking water during that time.

What Should I Do?

This notice is to inform you that Apollo Mobile home Park did not monitor and report results for the presence of total chlorine in the public drinking water system during the January 2013 time period, as required by the Ohio Environmental Protection Agency. You do not need to take any action in response to this notice.

What is being done?

Upon being notified of this violation, the water supply was required to have the drinking water analyzed for the above mentioned parameters. The water supplier will take steps to ensure that adequate monitoring will be performed in the future.

For more information, please contact _____ at _____ or _____.
name of contact phone number mailing address

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID#: _____ STUID#: _____ Date distributed: _____

**PUBLIC NOTICE INSTRUCTIONS AND VERIFICATION FORM FOR
COMMUNITY PUBLIC WATER SYSTEMS WITH TIER 3 VIOLATIONS**

The owner or operator of a community public water system with a Tier 3 violation or situation shall notify the persons served by the public water system as soon as practical but **no later than one year** after the system learns of the violation. At a minimum, community public water systems must issue the notice **by mail or other direct delivery**. Public notice issued by methods other than posting shall be repeated annually as long as the violation or situation persists.

I HEREBY CERTIFY THAT THE PUBLIC WAS NOTIFIED BY THE FOLLOWING METHOD(S) INDICATED BELOW, AS DESCRIBED IN THE OHIO ADMINISTRATIVE CODE RULE 3745-81-32:

Required Method of Public Notification	Actual Method of Public Notification
<p>Use the following method to reach all persons served by the public water system:</p> <p>Public notice issued by mail or other direct delivery to each customer receiving a bill and to other service connections to which water is delivered by the public water system. The consumer confidence report delivered to customers by July 1 of each year may be used as long as the public notice includes all the required content and is delivered within the required timeframe.</p>	<p>Describe actual methods used to notify public of the violation:</p> <p>A. Date of mailing/delivery _____</p>
<p>If the above methods do not reach all persons served, also use any other method reasonably calculated to reach other persons regularly served by the public water system (e.g. publication in a local newspaper, delivery of multiple copies for distribution by customers that provide their drinking water to others, posting in public places served by the system or on the Internet, or delivery to community organizations). If the notice is posted, it shall remain in place as long as the violation exists, but in no case less than 7 days.</p>	<p>A. Method(s) _____ _____ _____</p> <p>B. Date(s) _____</p>

Please check if the public notice used was provided by Ohio EPA (other side of this form) or another acceptable notice was used:

- ____ A public notice as shown on the other side of this sheet was issued without changes.
- ____ A different public notice was issued. **INCLUDE A COPY OF THE PUBLIC NOTICE.**

Signature of Responsible Person Date

Printed Name and Title of Responsible Person

PWS NAME:
PWSID: OH
Facility ID:
County:
Type M/R
Time Period

<p><u>For Ohio EPA use only:</u> Date PN received: _____ PN acceptable: _____ PN not acceptable: _____</p>
--