



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



March 12, 2013

NOTICE OF VIOLATION – ACTION REQUIRED

Ms. Kathy Miller
Pit Stop Tavern
160 State Hwy 29 West
Celina, Ohio 45822

Mercer County
Pit Stop Tavern
Transient Non-Community PWS
PWS ID: OH5434712

Dear Ms. Miller:

The Public Water System serving Pit Stop Tavern is in violation of the Ohio Administrative Code (OAC) for:

Failure to respond in Writing within 30 days

This letter is notification that the Pit Stop Tavern has not complied with requirements issued during this Agency's last survey performed on January 28, 2013, in violation of rule 3745-81-60 of the Ohio Administrative Code. The PWS was notified in correspondence dated February 5, 2013, to respond in writing no later than 30 days, with time frames for:

1. OAC Rule 3745-9-05 (O) states, "Well casing height above finished grade shall be at least twelve inches..." In addition, OAC Rule 3745-9-05 (O)(2) states, "The finished grade shall be sloped for surface water runoff away from the well."

Grade the area around the well to ensure water runs away from the base of the well.

2. OAC Rule 3745-7-09(A) specifies "The owner and operator of record of a public water system, treatment works or sewerage system shall maintain or cause to be maintained operation and maintenance records for each public water system, water treatment plant within a public water system, treatment works, or wastewater treatment facility within a treatment works."

Maintain records that meet the applicable requirements of OAC Rule 3745-7-09 as provided and reviewed during the survey.

A responsible official of the public water system must respond, **in writing, within 15 days**, indicating how and on what schedule the system will address the above requirements. If you have any questions, please contact me at (419) 373-3101 or by e-mail at chris.riddle@epa.ohio.gov.

Sincerely,

Chris Riddle
Division of Drinking and Ground Waters

//lr
pc: DDAGW – NWDO File

