



Environmental
Protection Agency

John Kasich, Governor
Robert Taft, Lt. Governor
Tom B. Frank, Director



January 4, 2011

RE: WAYNE COUNTY
RAYCO MANUFACTURING, INC.
NON-TRANSIENT, NON-COMMUNITY WATER SYSTEM
PWS ID # OH8560012; STU ID# 8559806

Mr. John Bowling
Rayco Manufacturing, Inc.
4255 East Lincoln Way
Wooster, OH 44691

Dear Mr. Bowling:

On December 6, 2010, this office received the November 2010 Monthly Operating Report (MOR form 5002) from Rayco Manufacturing, Inc. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Rayco treats its water by chlorination (oxidation and disinfection) and green sand filtration (iron and manganese removal), you are required to conduct monitoring for chlorine residuals, iron, and manganese.

Please note the following violations:

- Ohio Administrative Code (OAC) 3745-83-01(G) requires a public water system serving fewer than two hundred and fifty persons that provides treatment to reduce iron and manganese shall monitor for iron and manganese at least monthly at each entry point into the distribution system using state certified laboratory.

No iron or manganese results were reported for the month of November 2010. Please note that we did receive separate laboratory reports for the iron and manganese results. Please enter these values on all future monthly reports.

- OAC 3745-83-01(G) requires a public water system that provides water treated with chlorine shall monitor for free and combined chlorine at least **once every day** that water is available to the public **at each entry point to the distribution system and a representative point in the distribution system.**

Chlorine residuals were reported for the distribution system only. Also, chlorine residuals are not being recorded on a daily basis. Please be reminded that chlorine must be monitored every day the water is available to the public.

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, beth.madis@epa.state.oh.us.

Sincerely,

Beth R. Madis, Environmental Specialist
Division of Drinking and Ground Waters

cc: Wayne County Health Department
Dave Bornino, Ohio EPA, Central Office, DDAGW
Tom Ciha, Rayco Manufacturing, Inc.

BM/ams