

**Environmental
Protection Agency****Governor
Lt. Governor
Director**

September 8, 2011

**RE: NOTICE OF VIOLATION
COLUMBIANA COUNTY
GUILFORD HIGHLANDS MHP
COMMUNITY WATER SYSTEM
PWS ID # OH1504112**Mr. Robert Dickey
12 W. Main Street
Canfield, OH 44406**CERTIFIED MAIL**

Dear Mr. Dickey:

This letter is notification that the Guilford Highlands Mobile Home Park (MHP) public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to monitor for both the free and combined chlorine residual at least once every day that water is available to the public at the entry point to the distribution system and at a representative point in the distribution system.

This violation of the OAC is based upon information submitted by the Guilford Highlands MHP public water system (PWS) as reported on Monthly Operating Report (MOR) #5002 for July 2011. Results reported on the form indicated 23 days where the chlorine residual was not monitored.

If you have any questions, please contact me directly at (330) 963-1248.

Respectfully,

A handwritten signature in black ink, appearing to read "J. Robert Henn".

J. Robert Henn
Environmental Specialist
Division of Drinking and Ground Waters

JRH/ams

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Kim Etters, Ohio EPA, NEDO, DDAGW