

**Environmental
Protection Agency**

2010
2010
2010
2010

Governor
Lt. Governor
Director



November 9, 2011

RE: MEDINA COUNTY
GRANGER LAKES CONDO #1
COMMUNITY WATER SYSTEM
PWS ID #OH5202112

Mr. K.J. Henderson, President
Board of Directors
Granger Lakes Condo #1
200 Granger Road
Medina, OH 44256

RE: NOTICE OF VIOLATION

Dear Mr. Henderson:

This letter is notification that the Granger Lakes Condo #1 public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to monitor for iron and hardness monthly and report the results on the required monthly operating report (MOR).

Due to arsenic levels above the MCL, green sand filters were installed for iron and arsenic removal in accordance with Detailed Plan Approval #441621 (11/15/2006). In addition, due to exceeding the action level for lead in 1993, a minimum hardness of 85 mg/l must be maintained to ensure that adequate calcium is available for corrosion control in accordance with the approved Lead and Copper Corrosion Control Recommendation NE-L123 (6/5/1996). In accordance with OAC Rule 3745-83-01, iron and hardness must be analyzed once a month from the entry point to the distribution system and reported on the monthly operating report submitted to this office for review.

Please advise me in writing within thirty (30) days of the receipt of this letter the steps that will be taken to ensure that these samples will be analyzed and reported as required. You were previously notified of this requirement during the last sanitary survey in correspondence dated May 5, 2009.

If you have any questions, please contact me directly at (330) 963-1235.

Respectfully,

Leslie Otten
Environmental Specialist
Division of Drinking and Ground Waters

LO:ds

cc: Mr. Don Martinson, Operator of Record