


**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**



November 2, 2011

RE: WAYNE COUNTY
RAYCO MANUFACTURING, INC.
NON-TRANSIENT, NON-COMMUNITY
PUBLIC WATER SYSTEM
PWS ID # OH8560012
STU ID # 8559806

Mr. John Bowling
Rayco Manufacturing, Inc.
4255 East Lincoln Way
Wooster, OH 44691

Dear Mr. Bowling:

On October 10, 2011, this office received the September 2011 Monthly Operating Report (MOR form 5002) from Rayco Manufacturing, Inc. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Rayco treats its water by chlorination (oxidation and disinfection) and green sand filtration (iron and manganese removal), you are required to conduct monitoring for chlorine residuals, iron, and manganese.

Please note the following violations:

- Ohio Administrative Code (OAC) 3745-83-01(G) requires a public water system serving fewer than 250 persons that provides treatment to reduce iron and manganese shall monitor for iron and manganese at least monthly at each entry point into the distribution system using state certified laboratory.

No iron or manganese results were reported for the month of September 2011. Please note that we did receive separate laboratory reports for the iron and manganese results. Please enter these values on all future monthly reports.

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194, or by e-mail at beth.madis@epa.state.oh.us.

Sincerely,

Beth R. Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

cc: Wayne County Health Department
Ohio EPA, Central Office, DDAGW
Tom Ciha, Rayco Manufacturing, Inc.