

**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



November 2, 2011

RE: WAYNE COUNTY
FOREST VIEW MOBILE HOME PARK
1644 SYLVAN RD., WOOSTER, OH
COMMUNITY WATER SYSTEM
PWS ID # OH8500712
STU ID # 8559595

Mr. Bernie Caldwell
P.O. Box 1824
Wooster, OH 44691

Dear Mr. Caldwell:

On October 7, 2011, this office received the September 2011 Monthly Operating Report (MOR form 5002) from Forest View Mobile Home Park PWS. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Forest View Mobile Home Park treats its water by softening (hardness removal) and chlorination (disinfection), you are required to conduct monitoring for hardness and chlorine residual.

Please note the following violation:

- Ohio Administrative Code (OAC) Section 3745-83-01 requires all community and major non-community water systems to maintain a minimum chlorine residual of at least 0.2 mg/L free chlorine, or 1.0 mg/L combined chlorine, measured at representative points throughout the distribution system. On 19 of 30 days during the month of September 2011, chlorine residuals were reported as less than 0.2 mg/L free chlorine, or 1.0 mg/L combined chlorine.

You must investigate the cause of the low chlorine levels and ensure the chlorine levels remain at an acceptable level.

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or by e-mail at beth.madis@epa.state.oh.us.

Sincerely,

Beth R. Madis, Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

cc: Wayne County Health Department
Ohio EPA, Central Office, DDAGW