

**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



June 3, 2011

RE: CARROLL COUNTY  
MOHAWK UTILITIES, INC.  
COMMUNITY WATER SYSTEM  
PWS ID. NO. 1000812  
STU ID. NO. 1053070 (PLANT NO. 1)  
STU ID. NO. 1053071 (PLANT NO. 2)

**NOTICE OF VIOLATION**

Mr. Jon Robertson, Superintendent  
Mohawk Utilities, Inc.  
7326 Canton Road, NW  
P.O. Box 566  
Malvern, OH 44644

Dear Mr. Robertson:

This office has reviewed the monthly operating reports for April 2011. The results indicate that on one occasion, an exceedance of the secondary Maximum Contaminant Level (MCL) for iron occurred at STU ID No. 1053070 (Plant No. 1). This exceedance included:

| <u>Date</u>    | <u>Contaminant</u> | <u>Level (milligrams/Liter) (mg/L)</u> |
|----------------|--------------------|--|
| April 25, 2011 | Iron               | 0.378                                  |


The Ohio Administrative Code (OAC) Rule 3745-82-02 has set the secondary MCL for iron at 0.3 mg/L. Be advised that the listed result is above the secondary MCL for iron. This office is requesting you provide an explanation of why the exceedance occurred. Submit your response to this office within 30 of the date of this letter.

Additionally, be reminded that OAC 3745-83-01-(G)(9)(b) requires **weekly** iron and manganese samples be monitored and reported from each treatment plant that removes iron and manganese that serves over 250 people. The April 2011 reports showed

MOHAWK UTILITIES, INC.  
JUNE 3, 2011  
PAGE 2 OF 2

irregularities in weekly reporting during the middle of the month. Ensure that iron and manganese samples are collected each week during the month.

Sincerely,



Cynthia M. Petretich  
Environmental Specialist  
Division of Drinking and Ground Waters

CMP:dms

pc: Dave Riley, Ohio EPA, DDAGW, CO  
Mike Santone, Ohio EPA, DDAGW, CO  
Kim Eters, Ohio EPA, DDAGW, NEDO  
Cliff Evans, PUCO

ec: Stivo DiFranco, Supervisor, Ohio EPA, DDAGW, NEDO