



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



July 12, 2011

RE: **NOTICE OF VIOLATION**
MAHONING COUNTY
M & C MOBILE VILLAGE
COMMUNITY WATER SYSTEM
PWS ID #OH5000912

Mr. Mitch Naumoff
M & C Corporation MHP
156 6th St. NW
Barberton, OH 44203

CERTIFIED MAIL

Dear Mr. Naumoff:

This letter is notification that the M & C Mobile Village public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information submitted by the M & C Mobile Village PWS as reported on Monthly Operating Report (MOR) #5002 for May 2011. Results reported on the form indicated 29 days where the minimum chlorine residual in the distribution system was less than 0.2 mg/L free chlorine residual.

An evaluation/investigation should be conducted to determine why the low residual occurred and what corrective action is necessary.

If you have any questions, please contact me directly at (330) 963-1269.

Respectfully,

Mandy Razzano
Environmental Specialist
Division of Drinking and Ground Waters

MR:ds

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Dan Hornoff