

**Environmental
Protection Agency****Governor
Lt. Governor
Director**

October 17, 2011

**RE: NOTICE OF VIOLATION
MEDINA COUNTY
MEDINA CO.- SHARON WADSWORTH
COMMUNITY WATER SYSTEM
PWS ID #OH5202003**Mr. James Troike, P.E.
Medina County Sanitary Engineer
P.O. Box 542
Medina, OH 44258**CERTIFIED MAIL**

Dear Mr. Troike:

This letter is notification that the Medina County-Sharon Wadsworth public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information reported on Monthly Operating Report (MOR) #5002 for the months of July and August 2011. Results reported on these forms documented three days in July and 15 days in August when the minimum chlorine residual in the distribution system was less than 0.2 mg/L free chlorine residual.

A booster chlorine station is currently under construction to serve this system. This station is being constructed to ensure that adequate chlorine residual will be maintained throughout this system in the future.

If you have any questions, please contact me directly at (330) 963-1235.

Respectfully,

A handwritten signature in cursive script that reads "Leslie Otten".

Leslie Otten
Environmental Specialist
Division of Drinking and Ground Waters

LO:ds

cc: Mr. David Ling, Water Dist. System Supervisor