



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



April 28, 2011

RE: PORTAGE COUNTY
PORTAGE CO - BRIMFIELD
COMMUNITY WATER SYSTEM
PWS ID. NO. 6706012

Mr. Lee Benson
Manager of Water & Monitoring
Portage County Water Resources
P.O Box 812
Ravenna, OH 44266

Dear Mr. Benson:

NOTICE OF VIOLATION

This letter is notice that the Portage County-Brimfield public water system is in violation of Ohio Revised Code Section 6109.20 for failure to provide a treated water fluoride level of 0.8 to 1.3 mg/L. The violations are noted below:

<u>DATE</u>	<u>PLANT TAP FLUORIDE LEVEL</u>
March 9, 2011	0.77 (mg/l)
March 10, 2011	0.78 (mg/l)
March 13, 2011	0.79 (mg/l)
March 14, 2011	0.78 (mg/l)
March 15, 2011	0.75 (mg/l)
March 16, 2011	0.75 (mg/l)
March 30, 2011	0.77 (mg/l)

In a follow-up telephone conversation with you, it was reported that the fluoride feeder had malfunctioned and that repairs have been made.

Please be advised that Portage County Water Resources is not required to issue a public notice for the above-mentioned violation.

If you should have any questions, please contact me directly at (330) 963-1235.

Sincerely,

Leslie Otten
Environmental Specialist
Division of Drinking and Ground Waters

LO:ds