



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

April 25, 2011

RE: PORTAGE COUNTY
VILLAGE OF WINDHAM
COMMUNITY WATER SYSTEM
PWS ID #OH6704812

NOTICE OF VIOLATION

Mr. Mike Iwanyckyj
Village Administrator
Village of Windham
9621 East Center Street
Windham, OH 44288

Dear Mr. Iwanyckyj:

This letter is notification that the Village of Windham public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-91-09 for failure of the approved treatment system to maintain compliance with the Manganese secondary MCL of 50 ug/l. Detailed plans for the existing water treatment plant were approved on April 18, 1985 including green sand filters for the removal of iron and manganese. The plant was placed into service in 1987.

The Monthly Operating Report (MOR) for the month of **March 2011** reported that the Manganese secondary MCL was exceeded in four out of the five samples collected with results ranging from 69 ug/l - 165 ug/l.

In addition, the Village of Windham was deficient in maintaining alkalinity within the ranges established in detailed plan approval dated October 2, 1995 for corrosion control. Alkalinity was not maintained within the approved range of 330 mg/l - 350 mg/l for at least 18 days during the month.

Please be reminded that no later than May 6, 2011 a letter must be submitted to this office establishing the steps that will be taken, with timeframes, to:

- (A) Evaluate the filters and filter operations and make necessary corrections to produce water that complies with the required secondary MCLs, and
- (B) Evaluate the chemical feed systems and operations and make necessary corrections to ensure compliance with the approved ranges for alkalinity, pH and hardness for corrosion control.

VILLAGE OF WINDHAM
APRIL 25, 2011
PAGE 2 OF 2

If you have any questions, please contact me directly at (330) 963-1235.

Respectfully,

A handwritten signature in cursive script that reads "Leslie Otten".

Leslie Otten
Environmental Specialist
Division of Drinking and Ground Waters

LO:ds

cc: Mr. Bruce Rininger, WTP Superintendent