

**Environmental
Protection Agency****Governor
Lt. Governor
Director**

September 8, 2011

**RE: NOTICE OF VIOLATION
SUMMIT COUNTY
NIMISILA MHP
COMMUNITY WATER SYSTEM
PWS ID # OH7702912**Ms. Michelle Jimenez
1529 Brittain Road #7
Akron, OH 44310**CERTIFIED MAIL**

Dear Ms. Jimenez:

This letter is notification that the Nimisila Mobile Home Park (MHP) public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information submitted by the Nimisila MHP public water system (PWS) as reported on Monthly Operating Report (MOR) #5002 for July 2011. Results reported on the form indicated five (5) days where the minimum chlorine residual in the distribution system was less than 0.2 mg/L free chlorine residual.

An evaluation/investigation should be conducted to determine why the low residual occurred and what corrective action is necessary. Please provide your findings to this writer by October 7, 2011.

If you have any questions, please contact me directly at (330) 963-1248.

Respectfully,

A handwritten signature in black ink, appearing to read "J. Robert Henn".

J. Robert Henn
Environmental Specialist
Division of Drinking and Ground Waters

JRH/ams

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Kim Eppers, Ohio EPA, NEDO, DDAGW